

WARNING NOTICE

No. 12614

EVERSOURCE

Name: GALLAN Date: 9-18-17
Address: 12 OAKLAND ST Town: MPO
Phone Number: _____
Person Notified: ANILE GALLAN

Violation Class:

- A
- B
- C

Actions Taken:

- Locked off at Meter
- Area isolated and shut off
- Shut off at appliance
- Left on

Potential Hazard: CARBON MONOXIDE

Town/City Gas inspection required before turning gas on Yes No

Appliance: _____

- Fuel line
- Vent System

Other: _____

Condition

- Improper Venting
- Excessive Carbon Monoxide
- Gas Leak
- Defective Safety
- Defective Heat Exchanger
- Improper clearance to combustibles

Other: _____

Comments: WALL HUNG BOILER MAKING EXCESS
CO - PEAK READ 500 PPM / NEEDS TO
BE CALIBRATED / ADJUSTED -

Tech ID: 300

Customer Signature: _____